

RSTC Enterprises Inc
2214 Heimstead Road
Eau Claire, WI 54703
715-830-9997



AC / DC Combiner enclosure: **Model 0760-41AD**
Asphalt/Cedar roof systems **Rated 600 VDC, 120 Amp**
120/240 VAC, 60 Amp

ETL Listed and labeled
Report # 3171411PRT-002 Revised April 22, 2010

- UL50 Type 3R, 11 Edition Electrical equipment enclosures
- UL 1741 1st Edition - inverters, converters, controllers, interconnection system equipment for distributed energy resources
- CSA C22.2 #107.1-01 General use power supplies enclosures (2006)

Basic specifications

Material - 18 Gauge Galvanized 90 Steel Base/Cover
Process - Seamless draw (stamped)
Flashing - 15" x 15"
Height - 3.25"
Cavity - 8" x 9" x 2.5" (162 Cubic inches)
Finish - Powder coat (1100 hours salt spray)

Assembly:

- Cavity Base and cover punched for matched assembly
- Base Flashing pre-punched for roof deck mounting
- Cavity Base - 5 predetermined dimples for fittings or conduit



Cover – Raised .625" for breaker clearance

Cover cutaway

Base plate:

- 16 gauge galvanized steel
- Fastened to base flashing with toggle fastening system
- Finish – Powder coat (1100 hours salt spray)
- 5 - Roof deck knockouts
- Knockout sizes – (3).5", (1).75" and (1)1"
- Electrical Component Rail - 7" slotted 35mm Installed with steel stud and star nut

Ground – Installed with steel stud and star nut
Dual position for Wire size - 2/0-14
Located with ground sticker

Strain Clip – Aluminum riveted installation

Hardware pack:

7 - 1" Truss head screws
4 - .5" 8-32 thread cutting screws
4 - Bonded seal washers #10
2 – 10-32 1/2" Steel studs
2 – 10-32 3/8" steel star nuts
1 – Foam gasket seal
1 – Installation manual